

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)	3 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
Asbestos (1094)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	3 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status		
82 LILIBRIDGE ROAD (G4549)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
Lead And Copper (PBCU)	20 routine (RT) per six months		
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status		
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Physical Parameters (PPS)	3 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		11/1/25 - 11/30/25		Complete
		12/1/25 - 12/31/25		Complete
		1/1/26 - 1/31/26		
		2/1/26 - 2/28/26		
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

Water System Facility: ENTRY POINT - WELL 1 (WSF ID: 00700)

Net Gross Alpha (4000)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Uranium (4006)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Combined Radium-226/228 (4010)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Gross Beta Particle Activity (4100)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Man-Made Beta Particle & Photon Emitters (4101)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Tritium (4102)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1 (WSF ID: 00700)

Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Water System Facility: ENTRY POINT - WELL 2 (WSF ID: 00701)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 2 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 2 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		977	82	26	

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 2 (WSF ID: 00701)

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL 2 (3)		1/1/24 - 12/31/32		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL 2 (3)		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL 2 (3)		1/1/25 - 12/31/25		
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Water System Facility: WELL 1 (WSF ID: 1215)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 1 (2)	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Water System Facility: WELL 2 (WSF ID: 1216)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 2 (2)	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Out of Service	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: WELL 2 (WSF ID: 1216)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1 (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003	Compliance History: Monitoring Period	Operating Limit	Monitoring
	8/1/2025 - 8/31/2025	Compliance Status:	Compliance Status:
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		G4549	82 LILIBRIDGE ROAD	A				Y
		G4550	44 RR AVE	A	Y			
		G4551	22 FERNWOOD ST	A		3		
		G4552	4 JAMES ST	A		3		
		G4553	1 MAPLESHADE AVE	A		3		
		G4554	40 MAPLESHADE AVE	A		3		
		G4555	12 EASY ST	A		N		
		G4556	15 ROBIN RD	A		3		
		G4557	55 BEECHWOOD BLVD	A		1		
		G4558	10 SPRING ST	A		N		
		G4559	19 EASY ST	A		3		
		G4560	1 ROBIN ST	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	977	82	26		

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier
					Asbestos	WQP 2 DBPR
	G4561	3 JAMES ST		A		3
	G4562	10 BIRCH ST		A		3
	G4563	30 FERNWOOD		A		3
	G4564	7 S. PINE ST		A		3
	G4565	12 JAMES ST		A		3
	G4566	1 JAMES ST		A		3
	G4567	13 FERNWOOD		A		3
	G4568	11 BUTTERNUT RD		A		3
	G4569	58 BEECHWOOD BLVD		A		3
	G4570	8 BEECHWOOD BLVD		A		3
	G4571	720 NORWICH ROAD		A	Y	
	G4572	4 WEST PARKWAY		A	Y	
	G4573	59 BEECHWOOD BLVD		A		1
	G4574	63 BEECHWOOD BLVD		A		1
	G4575	67 BEECHWOOD BLVD		A		1
	G4576	68 BEECHWOOD BLVD		A		1
	G4577	71 BEECHWOOD BLVD		A		1
	G4578	72 BEECHWOOD BLVD		A		1
	G4579	75 BEECHWOOD BLVD		A		1
	G4580	76 BEECHWOOD BLVD		A		1
	G4581	5 BLOOM DR		A		1
	G4582	7 BLOOM DR		A		1
	G4583	8 BLOOM DR		A		1
	G4584	9 BLOOM DR		A		1
	G4585	11 BLOOM DR		A		1
	G4586	14 BLOOM DR		A		1
	G4587	15 BLOOM DR		A		1
	G4588	18 BLOOM DR		A		1
	G4589	4 CARRIE LANE		A		1
	G4590	7 CHARLES ST		A		1
	G4591	22 COLONIAL RD		A		1
	G4592	26 COLONIAL RD		A		1
	G4593	30 COLONIAL RD		A		1
	G4594	32 COLONIAL RD		A		1
	G4595	34 COLONIAL RD		A		1
	G4596	3 CONNECTICUT DR		A		1
	G4597	7 CONNECTICUT DR		A		1
	G4598	15 CONNECTICUT DR		A		1

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		977	82	26	

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	G4599	21 CONNECTICUT DR		A		1			
	G4600	26 CONNECTICUT DR		A		1			
	G4601	28 CONNECTICUT DR		A		1			
	G4602	29 CONNECTICUT DR		A		1			
	G4603	30 CONNECTICUT DR		A		1			
	G4604	34 CONNECTICUT DR		A		1			
	G4605	35 CONNECTICUT DR		A		1			
	G4606	36 CONNECTICUT DR		A		1			
	G4607	40 CONNECTICUT DR		A		1			
	G4608	41 CONNECTICUT DR		A		1			
	G4609	42 CONNECTICUT DR		A		1			
	G4610	44 CONNECTICUT DR		A		1			
	G4611	46 CONNECTICUT DR		A		1			
	G4612	48 CONNECTICUT DR		A		1			
	G4613	49 CONNECTICUT DR		A		1			
	G4614	50 CONNECTICUT DR		A		1			
	G4615	60 CONNECTICUT DR		A		1			
	G4616	8 ERIN DR		A		1			
	G4617	13 ERIN DR		A		1			
	G4618	21 ERIN DR		A		1			
	G4619	40 ERIN DR		A		1			
	G4620	48 ERIN DR		A		1			
	G4621	12 HEMLOCK DR		A		1			
	G4622	30 HEMLOCK DR		A		1			
	G4623	5 JAMES ST		A		1			
	G4624	21 OAKWOOD BLVD		A		1			
	G4625	40 PARK AVE		A		1			
	G4626	18 BEECHWOOD BLVD		A		3			
	G4627	24 BEECHWOOD BLVD		A		3			
	G4628	28 BEECHWOOD BLVD		A		3			
	G4629	33 BEECHWOOD BLVD		A		3			
	G4630	34 BEECHWOOD BLVD		A		3			
	G4631	39 BEECHWOOD BLVD		A		3			
	G4632	42 BEECHWOOD BLVD		A		3			
	G4633	49 BEECHWOOD BLVD		A		3			
	G4634	50 BEECHWOOD BLVD		A		3			
	G4635	53 BEECHWOOD BLVD		A		3			
	G4636	64 BEECHWOOD BLVD		A		3			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		977	82	26	

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
					Rule	Asbestos			
		G4637	44 ERIN DR	A		3			
		G4638	47 FERNWOOD ST	A		3			
		G4639	48 FERNWOOD ST	A		3			
		G4640	9 GOLDEN DR	A		3			
		G4641	33 MAPLESHADE AVE	A		3			
		G4642	39 MAPLESHADE AVE	A		3			
		G4643	9 OAK ST	A		3			
		G4644	11 OAKWOOD BLVD	A		3			
		G4645	14 OAKWOOD BLVD	A		3			
		G4646	25 OAKWOOD BLVD	A		3			
		G4647	31 OAKWOOD BLVD	A		3			
		G4648	35 OAKWOOD BLVD	A		3			
		G4649	39 OAKWOOD BLVD	A		3			
		G4650	45 OAKWOOD BLVD	A		3			
		G4651	48 OAKWOOD BLVD	A		3			
		G4652	54 OAKWOOD BLVD	A		3			
		G4653	55 OAKWOOD BLVD	A		3			
		G4654	59 OAKWOOD BLVD	A		3			
		G4655	60 OAKWOOD BLVD	A		3			
		G4656	64 OAKWOOD BLVD	A		3			
		G4657	65 OAKWOOD BLVD	A		3			
		G4658	67 OAKWOOD BLVD	A		3			
		G4659	17 PINE ST	A		3			
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT - WELL 1	3	EP - WELL 1	A					
00701	ENTRY POINT - WELL 2	3	EP - WELL 2	A					
1215	WELL 1	2	WELL 1	A					
1216	WELL 2	2	WELL 2	A					
224	GALLUP WATER SERVICE - WELL 1								
46521	PARK AVE PRESSURE TANKS								
46523	PLAINFIELD INDUSTRIAL PARK TANK 1								
46525	PLAINFIELD INDUSTRIAL PARK TANK 2								
52581	RUTH DRIVE PUMP STATION								
61526	GALLUP WATER SERVICE - WELL 2								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		977	82	26	

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Status	Lead and Coliform Rule	Copper Rule Tier	Stage Asbestos WQP 2 DBPR
62072	INTERCONNECTION - CT1090081 - PLAINFIELD						

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:		Certification Expiration
CLASS 1 DISTRIBUTION SYSTEM		
Operator Name	Operator Type	Certification(s)
CONNORS, JAMES	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III

Water System Facility: **GALLUP WATER SERVICE - WELL 1 (WSF ID: 224)**

Facility Classification:		Certification Expiration
CLASS 1 TREATMENT PLANT		
Operator Name	Operator Type	Certification(s)
SEHL, ROBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II
		DISTRIBUTION SYSTEM OPERATOR - CLASS II
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I

Water System Facility: **GALLUP WATER SERVICE - WELL 2 (WSF ID: 61526)**

Facility Classification:		Certification Expiration
CLASS 1 TREATMENT PLANT		
Operator Name	Operator Type	Certification(s)
WILCOX, MELISSA	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I

Contact Information

Name	Organization	Job Title
Mr. Craig J. Patla	Connecticut Water Company	Vp, Service Delivery
Mailing Address Line One	Mailing Address Line Two	City
93 West Main Street		State
Business Phone	Extension	Zip Code
860-664-6140		
800-391-1924	craig.patla@ctwater.com	

Contact Role(s):	Legal Contact, Owner				
Name	Organization			Job Title	
Mr. Paul C. Lowry	Connecticut Water Company			Manager	
Mailing Address Line One	Mailing Address Line Two			City	State
93 W Main Street				Clinton	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-944-9655		860-654-1903		800-208-5700	ctwcdphadmin@ctwater.com

Contact Role(s): **Administrative Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		605	44	7	20

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Chlorine Residual (1012)	2 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
Asbestos (1094)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	2 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
219 MAIN ST, MOOSUP (P4450)	1/1/25 - 12/31/25	8/10-8/16	Complete
	1/1/26 - 12/31/26	8/10-8/16	
	1/1/27 - 12/31/27	8/10-8/16	
Lead And Copper (PBCU)	20 routine (RT) per six months		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Physical Parameters (PPS)	2 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		605	44	7	20

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	2 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **TREATMENT PLANT** (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Water System Facility: **WELL 1** (WSF ID: 1330)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 1330)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 2 (WSF ID: 1331)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2008	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility: TREATMENT PLANT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2008		Compliance History: Operating Limit	Monitoring
		Monitoring Period	Compliance Status:
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 4/1/2009		Compliance History: Operating Limit	Monitoring
		Monitoring Period	Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 4/1/2009		Compliance History: Operating Limit	Monitoring
		Monitoring Period	Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	WQP 2 DBPR	Stage
					Rule	Tier	Stage	Stage	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		P4450	219 MAIN ST, MOOSUP	A	Y				
		P4451	57 WAUREGAN RD	A	Y				
		P4452	37 CHARLOTTE DR	A		1			
		P4453	18 CHARLOTTE DR	A		1			
		P4454	22 CHARLOTTE DR	A		1			
		P4455	21 CHARLOTTE DR	A		1			
		P4456	4 CHARLOTTE DR	A		1			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		P4457	8 CHARLOTTE DR	A		1		
		P4458	38 CHARLOTTE DR	A		1		
		P4459	27 CHARLOTTE DR	A		1		
		P4460	28 CHARLOTTE DR	A		1		
		P4461	32 CHARLOTTE DR	A		1		
		P4462	234 SHEPARD HILL RD.	A	Y			
		P4463	9 LORI DR.	A	Y			
		P4464	112 E SHEPARD HILL R	A	Y	1		
		P4465	79 CRANSKA OAKS RD	A	Y	1		
		P4466	5 CHARLOTTE DR	A	Y	1		
		P4467	11 CHARLOTTE DR	A	Y	1		
		P4468	12 CHARLOTTE DR	A	Y	1		
		P4469	17 CHARLOTTE DR	A	Y	1		
		P4470	33 CHARLOTTE DR	A	Y	1		
		P4471	209 SHEPARD HILL RD	A	Y	1		
		P4472	225 SHEPARD HILL RD	A	Y	1		
		P4473	229 SHEPARD HILL RD	A	Y	1		
		P4474	235 SHEPARD HILL RD	A	Y	1		
		P4475	249 SHEPARD HILL RD	A	Y	1		
		P4476	106 E SHEPARD HILL R	A	Y	3		
		P4477	40 MAIN ST	A	Y	3		
		P4478	15 PUTNAM RD	A	Y	3		
		P4479	17 PUTNAM RD	A	Y	3		
		P4480	43 ALLEN ST	A	Y	3		
		P4481	61 ALLEN ST	A	Y	3		
		P4482	6 BITGOOD VILLAGE	A	Y	3		
		P4483	7 BITGOOD VILLAGE	A	Y	3		
		P4484	10 BITGOOD VILLAGE	A	Y	3		
		P4485	15 BITGOOD VILLAGE	A	Y	3		
		P4486	22 BITGOOD VILLAGE	A	Y	3		
		P4487	23 BITGOOD VILLAGE	A	Y	3		
		P4488	27 BITGOOD VILLAGE	A	Y	3		
		P4489	32 BITGOOD VILLAGE	A	Y	3		
		P4490	34 BITGOOD VILLAGE	A	Y	3		
		P4491	36 BITGOOD VILLAGE	A	Y	3		
		P4492	26 BITGOOD VLG	A	Y	3		
		P4493	35 CHURCH ST	A	Y	3		
		P4494	51 CRANSKA OAKS RD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	3	Y	3
		P4495	67 CRANSKA OAKS RD	A	Y	3		
		P4496	75 CRANSKA OAKS RD	A	Y	3		
		P4497	1 CRANSKA RD	A	Y	3		
		P4498	21 CRANSKA RD	A	Y	3		
		P4499	77 CRANSKA RD	A	Y	3		
		P4500	28 DAGGETT ST	A	Y	3		
		P4501	48 DAGGETT ST	A	Y	3		
		P4502	55 DAGGETT ST	A	Y	3		
		P4503	63 DAGGETT ST	A	Y	3		
		P4504	18 GROVE ST	A	Y	3		
		P4505	8-10 LAKE ST	A	Y	3		
		P4506	4 LINNELL ST	A	Y	3		
		P4507	16 LINNELL ST	A	Y	3		
		P4508	17 LINNELL ST	A	Y	3		
		P4509	25 LINNELL ST	A	Y	3		
		P4510	51 MAIN ST	A	Y	3		
		P4511	57 MAIN ST	A	Y	3		
		P4512	77 MAIN ST	A	Y	3		
		P4513	87 MAIN ST	A	Y	3		
		P4514	121 MAIN ST	A	Y	3		
		P4515	133 MAIN ST	A	Y	3		
		P4516	143 MAIN ST	A	Y	3		
		P4517	179 MAIN ST	A	Y	3		
		P4518	191 MAIN ST	A	Y	3		
		P4519	6 POTVIN AVE	A	Y	3		
		P4520	30 POTVIN AVE	A	Y	3		
		P4521	85 PROSPECT ST	A	Y	3		
		P4522	40 RIVER ST	A	Y	3		
		P4523	21 TURCOTTE AVE	A	Y	3		
		P4524	23 TURCOTTE AVE	A	Y	3		
		P4525	29 UNION ST	A	Y	3		
		P4526	1 BLUEBERRY LANE	A	Y	3		
		P4527	2 BLUEBERRY LANE	A	Y	3		
		P4528	3 BLUEBERRY LANE	A	Y	3		
		P4529	4 BLUEBERRY LANE	A	Y	3		
		P4530	6 BLUEBERRY LANE	A	Y	3		
		P4531	5 BLUEBERRY LANE	A	Y	3		
		P4532	7 BLUEBERRY LANE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
		P4533	8 BLUEBERRY LANE	A	Y	3
		P4534	4 GROVE ST	A	Y	3
		P4535	2 MOOSUP POND RD	A	Y	3
		P4536	4 MOOSUP POND RD	A	Y	3
		P4537	8 MOOSUP POND RD	A	Y	3
		P4538	12 MOOSUP POND RD	A	Y	3
		P4539	1 PATTY LANE	A	Y	3
		P4540	2 PATTY LANE	A	Y	3
		P4541	3 PATTY LANE	A	Y	3
		P4542	4 PATTY LANE	A	Y	3
		P4543	5 PATTY LANE	A	Y	3
		P4544	6 PATTY LANE	A	Y	3
		P4545	2 PLAINVIEW DR	A	Y	3
		P4546	3 PLAINVIEW DR	A	Y	3
		P4547	4 PLAINVIEW DR	A	Y	3
		P4548	5 PLAINVIEW DR	A	Y	3
		P4549	6 PLAINVIEW DR	A	Y	3
		P4550	7 PLAINVIEW DR	A	Y	3
		P4551	193 SHEPHERD HILL RD	A	Y	3
		P5000	MARIE ST SMP STAT	A	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A		
00700	TREATMENT PLANT	3	ENTRY POINT	A		
1330	WELL 1	2	WELL 1	A		
1331	WELL 2	2	WELL 2	A		
1332	WELL 3	2	WELL 3	A		
46519	STORAGE TANK 2					
62074	INTERCONNECTION - CT1090031 - GALLUP					
62387	PATTY LANE TANK					

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
CONNORS, JAMES	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III
LEPINE, TODD	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 00700)

Facility Classification: CLASS 1 TREATMENT PLANT

**Certification
Expiration**

Operator Name	Operator Type	Certification(s)	
WILCOX, MELISSA	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2028
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Contact Information

Name	Organization	Job Title		
Mr. Craig J. Patla	Connecticut Water Company	Vp, Service Delivery		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 West Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-664-6140				800-391-1924 craig.patla@ctwater.com

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title		
Mr. Paul C. Lowry	Connecticut Water Company	Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 W Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-944-9655		860-654-1903		800-208-5700 ctwcdphadmin@ctwater.com

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		24			Agricultural

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/26 - 6/30/26		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		1/1/29 - 12/31/31		1 routine (RT) per three years

Water System Facility: WELL 1 (WSF ID: 1103)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	WELL 2 (2)	8/1/25 - 8/31/25		Complete
		9/1/25 - 9/30/25		Complete
		10/1/25 - 10/31/25		Complete
		11/1/25 - 11/30/25		Complete
		12/1/25 - 12/31/25		Complete
		1/1/26 - 1/31/26		
		2/1/26 - 2/28/26		
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION		3/1/2029

Water System Facility and Sampling Point Inventory										
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR	Stage
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		UPSTREAM	WITHIN 5 SERVICE CON	A						
		WT001	1 TERRACE DRIVE	A	Y		N			
		WT002	2 TERRACE DRIVE	A			N			
		WT003	3 TERRACE DRIVE	A	Y		N			
		WT004	4 TERRACE DRIVE	A			N			
		WT005	5 TERRACE DRIVE	A	Y		N			
		WT006	6 TERRACE DRIVE	A			N			
		WT007	7 TERRACE DRIVE	A			N			
		WT008	8 TERRACE DRIVE	A			N			
		WT009	9 TERRACE DRIVE	A			N			
		WT010	10 TERRACE DRIVE	A			N			
		WT011	11 TERRACE DRIVE	A			N			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	24				

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
	WT012	12 TERRACE DRIVE		A	Y	N		
	WT013	13 TERRACE DRIVE		A		N		
	WT014	14 TERRACE DRIVE		A		N		
	WT015	15 TERRACE DRIVE		A		N		
	WT016	16 TERRACE DRIVE		A		N		
	WT017	17 TERRACE DRIVE		A		N		
	WT018	18 TERRACE DRIVE		A		N		
	WT019	19 TERRACE DRIVE		A		N		
	WT020	20 TERRACE DRIVE		A		N		
	WT021	21 TERRACE DRIVE		A		N		
	WT022	22 TERRACE DRIVE		A		N		
	WT023	23 TERRACE DRIVE		A	Y	N		
	WT024	24 TERRACE DRIVE		A		N		
	WT025	25 TERRACE DRIVE		A		N		
00700	ENTRY POINT	3	ENTRY POINT	A				
1103	WELL 1	2	WELL 2	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:	SMALL WATER SYSTEM		Certification Expiration
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027 9/30/2027
LAFRAMBOISE, ERIC	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026 9/30/2026
STARK, TYLER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028 3/31/2028

Contact Information

Name	Organization	Job Title
Mr. Matthew J Ricciardella	Crystal View Capital	Manager
Mailing Address Line One	Mailing Address Line Two	City
9515 Hillwood Dr.		State
		Zip Code
Business Phone	Extension	Fax
702-541-6379		
Mobile Phone	Emergency Phone	Email Address
	959-207-8240	jenniferm@crystalviewcapital.com
Contact Role(s):	Owner	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential 24	Commercial	Industrial	Combined

Towns Served: PLAINFIELD

Name	Organization	Job Title		
Ms. Jennifer Marzan	Crystal View Capital	Development Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
9515 Hillwood Drive		Las Vegas	NV	89134
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
702-541-6379				702-546-7226
				jenniferm@crystalviewcapital.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
10 GORMAN ST, MOOSUP	Connections	89			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	10 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
10 GORMAN ST, MOOSUP	Connections	89			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
10 GORMAN ST, MOOSUP	Connections	89			

Towns Served: PLAINFIELD

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	<spaces> ()	Maximum: 3.0 MG/L	2	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.5 MG/L	2	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	N	
		9/1/2025 - 9/30/2025	N	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	N	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.3 PH	Daily	
Start Date: 9/1/2016		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	N	
		10/1/2025 - 10/31/2025	N	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	<spaces> ()	Maximum: 7.8 PH	Daily	
Start Date: 9/1/2016		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	<spaces> ()	Minimum: 0.1 MG/L	2	
Start Date: 9/1/2016		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
10 GORMAN ST, MOOSUP	Connections	89			

Towns Served: PLAINFIELD

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	0.1 MG/L	2	Monitoring
Phosphate (as PO4)	<spaces> ()				Compliance Status:
Start Date:	9/1/2016	Monitoring Period	Operating Limit	Monitoring	Compliance Status:
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
				Status	Coliform Rule				
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y	2	Y	Y	Y
		BLDG1-001A	APT 1A KITCHEN	A	Y				
		BLDG1-001B	APT 1B KITCHEN	A	Y				
		BLDG1-001C	APT 1C KITCHEN	A	Y				
		BLDG1-001D	APT 1D KITCHEN	A	Y				
		BLDG1-001E	APT 1E KITCHEN	A	Y				
		BLDG1-001F	APT 1F KITCHEN	A	Y				
		BLDG1-001G	APT 1G KITCHEN	A	Y				
		BLDG1-001H	APT 1H KITCHEN	A	Y				
		BLDG1-001I	APT 1I KITCHEN	A	Y				
		BLDG1-001J	APT 1J KITCHEN	A	Y				
		BLDG10-COMM	BUILDING 10 KITCHEN	A	Y				
		BLDG2-002A	APT 2A KITCHEN	A	Y				
		BLDG2-002B	APT 2B KITCHEN	A	Y				
		BLDG2-002C	APT 2C KITCHEN	A	Y				
		BLDG2-002D	APT 2D KITCHEN	A	Y				
		BLDG2-002E	APT 2E KITCHEN	A	Y				
		BLDG2-002F	APT 2F KITCHEN	A	Y				
		BLDG2-002G	APT 2G KITCHEN	A	Y				
		BLDG2-002H	APT 2H KITCHEN	A	Y				
		BLDG2-002I	APT 2I KITCHEN	A	Y				
		BLDG2-002J	APT 2J KITCHEN	A	Y				
		BLDG3-003A	APT 3A KITCHEN	A	Y				
		BLDG3-003B	APT 3B KITCHEN	A	Y				
		BLDG3-003C	APT 3C KITCHEN	A	Y				
		BLDG3-003D	APT 3D KITCHEN	A	Y				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
10 GORMAN ST, MOOSUP	89				

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory										
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR	Stage
	BLDG3-003E	APT 3E KITCHEN		A	Y	2				
	BLDG3-003F	APT 3F KITCHEN		A	Y	2				
	BLDG3-003G	APT 3G KITCHEN		A	Y	2				
	BLDG3-003H	APT 3H KITCHEN		A	Y	2				
	BLDG3-003I	APT 3I KITCHEN		A	Y	2				
	BLDG3-003J	APT 3J KITCHEN		A	Y	2				
	BLDG4-004A	APT 4A KITCHEN		A	Y	2				
	BLDG4-004B	APT 4B KITCHEN		A	Y	2				
	BLDG4-004C	APT 4C KITCHEN		A	Y	2				
	BLDG4-004D	APT 4D KITCHEN		A	Y	2				
	BLDG4-004E	APT 4E KITCHEN		A	Y	2				
	BLDG4-004F	APT 4F KITCHEN		A	Y	2				
	BLDG4-004G	APT 4G KITCHEN		A	Y	2				
	BLDG4-004H	APT 4H KITCHEN		A	Y	2				
	BLDG4-004I	APT 4I KITCHEN		A	Y	2				
	BLDG4-004J	APT 4J KITCHEN		A	Y	2				
	BLDG5-005A	APT 5A KITCHEN		A	Y	2				
	BLDG5-005B	APT 5B KITCHEN		A	Y	2				
	BLDG5-005C	APT 5C KITCHEN		A	Y	2				
	BLDG5-005D	APT 5D KITCHEN		A	Y	2				
	BLDG5-005E	APT 5E KITCHEN		A	Y	2				
	BLDG5-005F	APT 5F KITCHEN		A	Y	2				
	BLDG5-005G	APT 5G KITCHEN		A	Y	2				
	BLDG5-005H	APT 5H KITCHEN		A	Y	2				
	BLDG5-005I	APT 5I KITCHEN		A	Y	2				
	BLDG5-005J	UNIT 5 ROOM 5J		A	Y					
	BLDG6-006A	APT 6A KITCHEN		A	Y	2				
	BLDG6-006B	APT 6B KITCHEN		A	Y	2				
	BLDG6-006C	APT 6C KITCHEN		A	Y	2				
	BLDG6-006D	APT 6D KITCHEN		A	Y	2				
	BLDG6-006E	APT 6E KITCHEN		A	Y	2				
	BLDG6-006F	APT 6F KITCHEN		A	Y	3				
	BLDG6-006G	APT 6G KITCHEN		A	Y	2				
	BLDG6-006H	APT 6H KITCHEN		A	Y	2				
	BLDG6-006I	APT 6I KITCHEN		A	Y	2				
	BLDG6-006J	APT 6J KITCHEN		A	Y	2				
	BLDG7-007A	APT 7A KITCHEN		A	Y	2				
	BLDG7-007B	APT 7B KITCHEN		A	Y	2				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
10 GORMAN ST, MOOSUP	89				

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	BLDG7-007C	APT 7C KITCHEN		A	Y	2			
	BLDG7-007D	APT 7D KITCHEN		A	Y	2			
	BLDG7-007E	APT 7E KITCHEN		A	Y	2			
	BLDG7-007F	APT 7F KITCHEN		A	Y	2			
	BLDG7-007G	APT 7G KITCHEN		A	Y	2			
	BLDG7-007H	APT 7H KITCHEN		A	Y	2			
	BLDG7-007I	APT 7I KITCHEN		A	Y	2			
	BLDG7-007J	APT 7J KITCHEN		A	Y	2			
	BLDG8-008A	APT 8A KITCHEN		A	Y	2			
	BLDG8-008B	APT 8B KITCHEN		A	Y	2			
	BLDG8-008C	APT 8C KITCHEN		A	Y	2			
	BLDG8-008D	APT 8D KITCHEN		A	Y	2			
	BLDG8-008E	APT 8E KITCHEN		A	Y	2			
	BLDG8-008F	APT 8F KITCHEN		A	Y	2			
	BLDG8-008G	APT 8G KITCHEN		A	Y	2			
	BLDG8-008H	APT 8H KITCHEN		A	Y	2			
	BLDG8-008I	APT 8I KITCHEN		A	Y	2			
	BLDG8-008J	APT 8J KITCHEN		A	Y	2			
	BLDG9-009A	APT 9A KITCHEN		A	Y	2			
	BLDG9-009B	APT 9B KITCHEN		A	Y	2			
	BLDG9-009C	APT 9C KITCHEN		A	Y	2			
	BLDG9-009D	APT 9D KITCHEN		A	Y	2			
	BLDG9-009E	APT 9E KITCHEN		A	Y	2			
	BLDG9-009F	APT 9F KITCHEN		A	Y	2			
	BLDG9-009G	APT 9G KITCHEN		A	Y	2			
	BLDG9-009H	APT 9H KITCHEN		A	Y	2			
	BLDG9-009I	APT 9I KITCHEN		A	Y	2			
	BLDG9-009J	APT 9J KITCHEN		A	Y	2			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A					
	UPSTREAM	WITHIN 5 SERVICE CON		A					
00700	ENTRY POINT	3	ENTRY POINT	A					
1102	WELL 1	2	WELL 1	A					
1106	WELL 2	2	WELL 2	A					
50602	ATMOSPHERIC STORAGE								
60286	TREATMENT PLANT								
61656	VFD TRANSFER PUMPS								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
10 GORMAN ST, MOOSUP	Connections	89			

Towns Served: PLAINFIELD

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 60286)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028 9/30/2027
HARKINS, STUART A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028 6/30/2028

Contact Information

Name	Organization	Job Title		
Mr. Arthur Greenblatt	Vesta Corporation	President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
175 Power Forest Drive		Weatogue	CT	06089
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-916-0258				
			Email Address	arthur@vestacorp.com

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title		
Mr. Paul Bearce	Vesta Management Corporation	Director, Phys Plant		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
175 Powder Forest Dr.		Weatogue	CT	06089
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-325-1700				860-325-1708
			Email Address	paul@vestacorp.com

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1094201	JUMBO APARTMENTS	C	35	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
164-168 PROSPECT ST	Connections	11			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1094201	JUMBO APARTMENTS	C	35	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
164-168 PROSPECT ST	Connections	11			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/26 - 6/30/26		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per six years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CROSS CONNECTION EXEMPTION	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		JA001	PUMP HOUSE	A			
		JA002	182 PROSPECT	A		3	
		JA003	164 PROSPECT	A	Y	3	
		JA004	166 PROSPECT	A		3	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1094201	JUMBO APARTMENTS	C	35	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
164-168 PROSPECT ST		11			

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Rule Tier	WQD	DBPR	
		JA005	168 PROSPECT	A		3		
		JA006	170 PROSPECT	A		3		
		JA007	172 PROSPECT	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1104	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:	SMALL WATER SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)		
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027	9/30/2027
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027	9/30/2027

Contact Information

Name	Organization	Job Title
Ms. Briana Paul	Prospect Rentals, LLC	
Mailing Address Line One	Mailing Address Line Two	City
123 Elvira Heights		State
		Zip Code
Business Phone	Extension	Fax
		Mobile Phone
		Emergency Phone
		860-377-9487
		Email Address
		jandbrirentals@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099131	MOOSUP MANOR	C	27	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
1 SARA LANE		1			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099131	MOOSUP MANOR	C	27	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
1 SARA LANE		1			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		1/1/27 - 12/31/29		1 routine (RT) per three years
Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/28		1 routine (RT) per six years
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/26 - 12/31/28	1/1/12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/29 - 12/31/31		1 routine (RT) per three years
Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	6/26/2022	
RESPOND TO SANITARY SURVEY	1/3/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	WQP 2 DBPR	Stage
					Rule Tier	2			
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		MW020	REC ROOM	A	Y				
		MW020-12	APT 12	A	Y	2			
		MW020-13	APT 13	A	Y				
		MW020-15	APT 15	A	Y				
		MW020-16	APT 16	A	Y				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099131	MOOSUP MANOR	C	27	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
1 SARA LANE		1			

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
		MW020-17	APT 17	A	Y		
		MW020-18	APT 18	A	Y		
		MW020-19	APT 19	A	Y		
		MW020-20	APT 20	A	Y		
		MW020-21	APT 21	A	Y		
		MW020-22	APT 22	A	Y	2	
		MW020-23	APT 23	A	Y		
		MW020-24	APT 24	A	Y	2	
		MW020-3	APT 3	A	Y	2	
		MW020-4	APT 4	A	Y	2	
		MW020-5	APT 5	A	Y		
		MW020-7	APT 7	A	Y		
		MW020-8	APT 8	A	Y		
		MW020-REC	REC ROOM	A	Y		
		MW027-REC	REC ROOM	A	Y		
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
1959	WELL 1	2	WELL 1	A			
51577	ATMOSPHERIC TANK						

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:	SMALL WATER SYSTEM	Certification Expiration	
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

Contact Information

Name	Organization			Job Title		
Ms. Pauline Galbreath	Rural Consulting & Management			Property Manager		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
Property Manager	P.O. Box 499			Dayville	CT	06241-0499
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-564-0838		860-564-6581			rcm550@aol.com	

Contact Role(s): **Administrative Contact, Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT1099131	MOOSUP MANOR				C	27	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
1 SARA LANE			1					
Towns Served: PLAINFIELD								
Name			Organization			Job Title		
Moosup Manor Partnership								
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
PO Box 499					Dayville	CT	06241	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

Contact Role(s): **Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099141	ARNIO DRIVE LLC	C	33	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
2-10 ARNIO DR	Connections	11			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per six years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/30		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099141	ARNIO DRIVE LLC	C	33	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
2-10 ARNIO DR	11				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION		3/1/2029

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule	Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	10 ARNIO	KITCHEN FAUCET	A	Y	N	Y	
		194 LAKE	KITCHEN FAUCET	A	Y	N	Y	
		196 LAKE	KITCHEN FAUCET	A	Y	N	Y	
		198 LAKE	KITCHEN FAUCET	A	Y	N	Y	
		2 ARNIO	KITCHEN FAUCET	A	Y	N	Y	
		200 LAKE	KITCHEN FAUCET	A	Y	N	Y	
		202 LAKE	KITCHEN FAUCET	A	Y	N	Y	
		204 LAKE	KITCHEN FAUCET	A	Y	N	Y	
		4	DISTRIBUTION	A				
		4 ARNIO	KITCHEN FAUCET	A	Y	N	Y	
		6 ARNIO	KITCHEN FAUCET	A	Y	N	Y	
		8 ARNIO	KITCHEN FAUCET	A	Y	N	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
53882	WELL 1	2	WELL 1	A				

Contact Information

Name	Organization	Job Title
Arnio Drive LLC		
Mailing Address Line One	Mailing Address Line Two	City
PO Box 874		State
Business Phone	Extension	Zip Code
860-481-3606		
Emergency Phone	Email Address	
	manager@arniodrive.com	
Contact Role(s): Legal Contact, Owner		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT1099141	ARNIO DRIVE LLC				C	33	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
2-10 ARNIO DR			11					
Towns Served: PLAINFIELD								
Name			Organization			Job Title		
Miss Suba Durairajan			Arnio Drive LLC			Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
550 South Street					Shrewsbury	MA	01545	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
773-630-9115				773-630-9115	suba.arun@gmail.com			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099181	MOOSUP POND TERRACE, LLC	C	46	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
MOOSUP POND RD	Connections	3			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	5 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099181	MOOSUP POND TERRACE, LLC	C	46	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
MOOSUP POND RD	Connections	3			

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	3/6/2021	
RESPOND TO SANITARY SURVEY	11/2/2023	
CROSS CONNECTION EXEMPTION	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
00600	DISTRIBUTION SYSTEM	267LB	267LB	A	Y	2	
		267LC	267LC	A	Y	2	
		267LPD	267LPD	A	Y	2	
		4	DISTRIBUTION SYSTEM	A			
		523MPC	523MPC	A	Y	2	
		523MPD	523MPD	A	Y	2	
		524 CC	APT 524 CC	A	Y		
		524 D	APT 524 D	A	Y		
		531 B	APT 531 B	A	Y		
		531 C	APT 531 C	A	Y		
		531 D	APT 531 D	A	Y		
		531MPA2	531MPA2	A	Y	2	
		531MPB2	531MPB2	A	Y	2	
		531MPC2	531MPC2	A	Y	2	
		531MPD2	531MPD2	A	Y	2	
00700	ENTRY POINT	DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		MPEP	ENTRY POINT	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
57833	WELL 1	2	WELL 1	A			
57835	WELL 2	2	WELL 2	A			
57839	WELL 2 TREATMENT PLANT						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099181	MOOSUP POND TERRACE, LLC	C	46	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
MOOSUP POND RD	3				

Towns Served: PLAINFIELD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NAPIERATA, KYLE	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027 9/30/2027
LAFRAMBOISE, PAUL F.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027 9/30/2027

Contact Information

Name	Organization	Job Title		
Baldi, LLC				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
349 Mack Road		Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title		
Mr. Alex Ilchenko				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
276 Main Street		Farmington	CT	06032
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.